

GSH
Güteschutzgemeinschaft
Hartschaum e.V.

CERTIFICATE OF CONFORMITY

on the basis of EN 13172, Annex A

Herewith we confirm that the

Thermal insulating products made of Bound EPS (BEPS)
Politerm Blu 300/Politerm Blu Fein 300/Poliplus Fein

(Product parameters see Annex 1)

from

TEKTO HELLAS S.A.
10 Zakka Street
56727 Neapoli
Thessaloniki, Greece


correspond to the technical specification

EN 16025-1:2013

The quality of the product and the factory production control are monitored through the certification process. As insulation component only HBCD-free EPS is used. This certificate of conformity is valid until **31.03.2022**. The validity can be prolonged by seal of the GSH and signature of the manager of the certification body.

16.03.2021 / 2021 7 875-1.e


Manager of the Certification Body
Corth Siegfried



Schildenstraße 24
D-29221 Celle
Notified Body 0919
UZ: UG 049



Tel +49 (0)5141-88 92 65
Fax +49 (0)5141-88 92 67
www.gsh.eu
info@gsh.eu

GSH

Güteschutzgemeinschaft Hartschaum e.V.

Annex 1 of the Certificate 875-1.e

Product name	Description	Thermal conductivity λ_0 at 10 °C W/mK	Bulk density	Compressive stress at 10% deformation	Particle size group	Reaction to fire class	Designation code of manufacturer
Politerm Blu 300	Mixed on site	0,084	300	700	PS6N - D0	A2 - s1, d0	BEPS - EN 16025-1 - PS6 - D0 - LD300 - MU5 - CS(10)700
Politerm Blu Fein 300	Mixed on site	0,084	300	700	PS5N - D0	A2 - s1, d0	BEPS - EN 16025-1 - PS5 - D0 - LD300 - MU5 - CS(10)700
Poliplus Fein	Premixed BEPS	0,084	300	700	PS5N - D0	A2 - s1, d0	BEPS - EN 16025-1 - PS5 - D0 - LD300 - MU5 - CS(10)700

This annex is valid until **31.03.2022**. The validity can be prolonged by seal of GSH and signature of the manager of the certification body.

16.03.2021 / 2021 7 875-1.e


 Manager of the certification body
 Corth Siegfried

Prolonged until:

Prolonged until:



Schildenstraße 24
D-29221 Celle
Notified Body 0919
ÜZ: UG 049

Tel +49 (0)5141-88 92 65
Fax +49 (0)5141-88 92 67
www.gsh.eu
info@gsh.eu